

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



## LISTING SERVICE

**LISTING No.** 7300-0328:0172 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042  
Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999  
Email: BillW@pottersignal.com

**DESIGN:** Models SB24-153075 (Selectable candela, 15cd or 30cd; tested to 75cd on-axis) and SB24-75110 (selectable candela, 75cd or 110cd) strobe lights synchronous or non-synchronous types, may be followed by -W or -R (White or Red outer cover). Intended for indoor use only; may be used outdoors when mounted to an Amseco weatherproof back-box; for wall mount only. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Regulated 24 DC = 16-33 Vdc  
Regulated 24 VFWR = 16-33 Vdc VFWR

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a signal appliance accessory for use with separately listed fire alarm control panels and audible devices.

**NOTE:**

12-21-2005 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2012**

Listing Expires **June 30, 2013**

Authorized By: **JASON DEWITT**, Deputy State Fire Marshal  
Fire Engineering Division